



*"The Capital City of the Palm Beaches"*

## PROCUREMENT DIVISION

1045 Charlotte Avenue  
West Palm Beach, FL 33401  
TEL: (561) 822-2100  
FAX: (561) 835-0028

### Addendum #2 Invitation to Bid #07/08-33

## DRAINAGE & UTILITY IMPROVEMENTS FOR EDMOR ROAD/LAKWOOD ROAD/GARDEN AVENUE

Each recipient of this Addendum No. 2 to the bid who responds to the bid acknowledges all of the provisions set forth in the Invitation to Bid and agrees to be bound by the terms thereof. This addendum shall modify, clarify, change or add information and clarification and become part of the above referenced Invitation to Bid.

The following changes/modifications are hereby made:

### TECHNICAL SPECIFICATIONS:

1. As a clarification add the following sentence to Section 01025, Measurement and Payment, Paragraph 3.08A, Remove & Dispose of Existing Asphalt Pavement (varying thickness): "Appendix B and D indicate that the existing asphalt pavement thickness varies from approximately 1 inch to 11 inches".
2. As a clarification add the following sentence to Section 01025, Measurement and Payment, Paragraph 3.08B, Remove & Dispose of Existing Road Base Material (varying thickness): "Appendix B and D indicate that the existing road base material thickness varies from approximately 6 inches to 9 inches and that poured concrete base material was not encountered."

### CONTRACT DOCUMENTS


1. Delete in its entirety Section 2 – Special Terms, pages 1 through 7.  
Add in its entirety the attached Section 2 – Special Terms, pages 1 through 7. The time of completion has been reworded in Phase II – Edmor Road, Part 4 and 5 and in Phase III – Garden Avenue, Part 1, 2, 3, and 4.

### PLANS

1. On Sheet T-2, Typical Sections, the typical section for Garden Avenue (Kifer Street to Hansen Street and Bradley Street to Briggs Street) shows one landscape at 9' wide and the other landscape area at 15' wide. Both existing landscape areas are approximately 9' wide.

Bidders must acknowledge receipt of this Addendum Number 2 in the space provided below. This Addendum forms an integral part of the bid documents and therefore must be executed. Failure to return this addendum with your bid submittal may be cause for disqualification.

Issued By: City of West Palm Beach  
Procurement Division  
June 2, 2008

Signed By:   
Nora W. Laudermilk  
Procurement Official

Bidder:

Signed By: \_\_\_\_\_

Print Name: \_\_\_\_\_

Title: \_\_\_\_\_

Date: \_\_\_\_\_

End of Addendum #2