



1. SERVICE LATERALS SHALL TERMINATE INSIDE PROPERTY LINE AT A MINIMUM DEPTH OF 3 FEET. HOWEVER, WHERE LOT SIZE IS SUCH THAT ADDITIONAL COVER IS REQUIRED TO MAINTAIN PLUMBING CODE REQUIREMENT FOR EFFLUENT PIPE FALL, MINIMUM DEPTH SHALL BE INCREASED ACCORDINGLY.
2. CLEAN-OUT CONNECTION TO BE RAISED TO FINISHED GRADE PRIOR TO WATER METER ACTIVATION.

REVISED: SEPT-2009	GRAVITY SEWER SYSTEM - HOUSE LATERAL CONNECTIONS	STANDARD DETAIL
ISSUED: SEPT - 2009	CITY OF WEST PALM BEACH ENGINEERING SERVICES DEPT.	GS-5