



1. WHEN SERVICE LINE DEPTH EXCEEDS 7 FT. OF COVER, WYE MAY BE INSTALLED ON VERTICAL SECTION WITH 3 FT. MIN. COVER.
2. CLEAN-OUT CONNECTION TO BE RAISED TO FINISHED GRADE PRIOR TO WATER METER ACTIVATION.

REVISED: SEPT-2009	GRAVITY SEWER SYSTEM - CLEAN-OUT	STANDARD DETAIL
ISSUED: SEPT - 2009	CITY OF WEST PALM BEACH ENGINEERING SERVICES DEPT.	GS-6