



1. CHAIN LINK FENCE W/ALL PARTS, INCLUDING POSTS & HARDWARE TO BE THERMALLY FUSED VINYL COATING OVER GALVANIZED STEEL. POSTS TO BE CORED AND GROUTED INTO CONCRETE. FABRIC TO BE KNUCKLED TOP & BOTTOM.
2. INDICATED LIMITS OF LIFT STATION EASEMENT ARE MINIMUM, SUBJECT TO ACTUAL WETWELL & PIPE SIZES.
3. ACCESS DOORS TO WETWELL TO BE CHECKERED PLATE ALUMINUM, WITH RECESSED HANDLES AND 361 STAINLESS STEEL HARDWARE AS SPECIFIED ON APPROVED MATERIALS LIST.
4. PROVIDE A.T.S. WITH GENERATOR RECEPTACLE ON DRIVEWAY SIDE.
5. PROVIDE A TRAILER MOUNTED STAND-BY GENERATOR WITH CRITICAL GRADE SILENCER 25 dBS @ 50 FEET. UNIT SHALL CONTAIN A FUEL TANK SIZED TO PROVIDE 48 HOURS OF CONTINUOUS OPERATION. CONNECT GENERATOR TO THE AUTOMATIC TRANSFER SWITCH VIA THE SIDE MOUNTED GENERATOR RECEPTACLE.
6. STEEL FOR CONCRETE SLAB #4 @ 12" O.C.B.W. & 4 SETS OF (2)#4 @ 4'-0" AROUND WETWELL.
7. GROUND ELECTRICAL SYSTEM TO REBAR IN CONCRETE. PAD.

| | | |
|------------------------|---|--------------------|
| REVISED: SEPT-2009 | SUBMERSIBLE LIFT STATION - TYPICAL LIFT STATION SITE PLAN | STANDARD DETAIL |
| ISSUED: SEPT - 2009 | CITY OF WEST PALM BEACH ENGINEERING SERVICES DEPT. | SLS-1 |